

KARNATAKA POWER CORPORATION LIMITED

Bellary Thermal Power Station

Installed Capacity : 2 Units x500 MW & 1 unit x700MW= 1700 MW

Month : April-2017

Sl.no	Parameter	Unit	UNIT 1 -3
1	Gross Generation	MU	295.17
2	Auxiliary Consumption	MU	19.32
3	Auxiliary Consumption	%	6.54
4	Net Generation	MU	275.87
5	Plant Availability Factor (PAF)	%	55.92
6	Plant Load Factor (PLF)	%	24.12
7	Forced Outages	No	1
8	Planned Outages	No	1
CUMULATIVE DATA FOR THE FINANCIAL YEAR :2017-18			
		Unit	
1	Generation unit 1-3	MU	295.17
2	Running Hours unit 1&2	Hrs	805:13:00