

**KARNATAKA POWER CORPORATION LIMITED**

**Bellary Thermal Power Station**

**Installed Capacity : 2 Units x500 MW & 1 unit x700MW= 1700 MW**

**Month : April - 2019**

| Sl.no  | Parameter                       | Unit | UNIT 1 -3  |
|--|---------------------------------|------|------------|
| 1  | Gross Generation                | MU   | 477.23     |
| 2  | Auxiliary Consumption           | MU   | 29.73      |
| 3  | Auxiliary Consumption           | %    | 6.23       |
| 4  | Net Generation                  | MU   | 447.50     |
| 5  | Plant Availability Factor (PAF) | %    | 62.93      |
| 6  | Plant Load Factor (PLF)         | %    | 38.99      |
| 7  | Forced Outages                  | No   | 3          |
| 8  | Planned Outages                 | No   | 0          |
| <b>CUMULATIVE DATA FOR THE FINANCIAL YEAR :2019-20</b> |                                 |      |            |
|  |                                 | Unit |            |
| 1  | Generation unit 1-3             | MU   | 4059.05    |
| 2  | Running Hours unit 1-3          | Hrs  | 1203:19:00 |