

KARNATAKA POWER CORPORATION LIMITED

Bellary Thermal Power Station

Installed Capacity : 2 Units x500 MW & 1 unit x700MW= 1700 MW

Month : February - 2019

Sl.no	Parameter	Unit	UNIT 1 -3
1	Gross Generation	MU	382.59
2	Auxiliary Consumption	MU	24.17
3	Auxiliary Consumption	%	6.32
4	Net Generation	MU	358.42
5	Plant Availability Factor (PAF)	%	66.22
6	Plant Load Factor (PLF)	%	33.49
7	Forced Outages	No	1
8	Planned Outages	No	0
CUMULATIVE DATA FOR THE FINANCIAL YEAR :2018-19			
		Unit	
1	Generation unit 1-3	MU	3504.51
2	Running Hours unit 1-3	Hrs	9431:13:00