

KARNATAKA POWER CORPORATION LIMITED

Bellary Thermal Power Station

Installed Capacity : 2 Units x500 MW & 1 unit x700MW= 1700 MW

Month : January-2018

Sl.no	Parameter	Unit	UNIT 1 -3
1	Gross Generation	MU	487.27
2	Auxiliary Consumption	MU	34.22
3	Auxiliary Consumption	%	7.02
4	Net Generation	MU	455.69
5	Plant Availability Factor (PAF)	%	73.38
6	Plant Load Factor (PLF)	%	38.53
7	Forced Outages	No	4
8	Planned Outages	No	0
CUMULATIVE DATA FOR THE FINANCIAL YEAR :2017-18			
		Unit	
1	Generation unit 1-3	MU	2918.50
2	Running Hours unit 1&2	Hrs	6826:07:00