

KARNATAKA POWER CORPORATION LIMITED

Bellary Thermal Power Station

Installed Capacity : 2 Units x500 MW & 1 unit x700MW= 1700 MW

Month : October -2018

Sl.no	Parameter	Unit	UNIT 1 -3
1	Gross Generation	MU	360.96
2	Auxiliary Consumption	MU	25.32
3	Auxiliary Consumption	%	7.11
4	Net Generation	MU	335.64
5	Plant Availability Factor (PAF)	%	59.76
6	Plant Load Factor (PLF)	%	28.54
7	Forced Outages	No	3
8	Planned Outages	No	0
CUMULATIVE DATA FOR THE FINANCIAL YEAR :2018-19			
		Unit	
1	Generation unit 1-3	MU	1788.93
2	Running Hours unit 1-3	Hrs	4664:17:00