

KARNATAKA POWER CORPORATION LIMITED

Bellary Thermal Power Station

Installed Capacity : 2 Units x500 MW & 1 unit x700MW= 1700 MW

Month : April -2018

| Sl.no | Parameter | Unit | UNIT 1 -3 |
|--|---------------------------------|------|-------------------|
| 1 | Gross Generation | MU | 642.13 |
| 2 | Auxiliary Consumption | MU | 39.37 |
| 3 | Auxiliary Consumption | % | 6.13 |
| 4 | Net Generation | MU | 602.78 |
| 5 | Plant Availability Factor (PAF) | % | 72.99 |
| 6 | Plant Load Factor (PLF) | % | 52.46 |
| 7 | Forced Outages | No | 3 |
| 8 | Planned Outages | No | 0 |
| CUMULATIVE DATA FOR THE FINANCIAL YEAR :2018-19 | | | |
| | | Unit | |
| 1 | Generation unit 1-3 | MU | 642.13 |
| 2 | Running Hours unit 1-3 | Hrs | 1576:34:00 |