

KARNATAKA POWER CORPORATION LIMITED

Bellary Thermal Power Station

Installed Capacity : 2 Units x500 MW & 1 unit x700MW= 1700 MW

Month : October - 2016

Sl.no	Parameter	Unit	UNIT 1 -3
1	Gross Generation	MU	636.41
2	Auxiliary Consumption	MU	39.16
3	Auxiliary Consumption	%	6.15
4	Net Generation	MU	599.37
5	Plant Availability Factor (PAF)	%	97.74
6	Plant Load Factor (PLF)	%	50.32
7	Forced Outages	No	1
8	Planned Outages	No	0
CUMULATIVE DATA FOR THE FINANCIAL YEAR :2016-17			
		Unit	
1	Generation unit 1-3	MU	3669.82
2	Running Hours unit 1&2	Hrs	7838:35:00